



## XFLAM FACTS

TECHNICAL  
BULLETIN

no.02

DATE: JUL 2005

### **XFLAM® PANEL**

### **BUILDING CODE OF AUSTRALIA MATERIAL CLASSIFICATION**

### **BUILDING MATERIALS USED IN AUSTRALIA ARE CLASSIFIED INTO GROUPS BASED ON FULL SCALE FIRE TESTING**

Xflam panel has been assessed against BCA 2005 using test standard ISO 9705: 1993. The test results qualify Xflam Panel when installed to the specification used in the test to a classification of Group 1.

*Test results:*

<i>BCA Classification</i>	<i>GROUP 1 – Does not reach flashover during test</i>
<i>Smoke Growth Rate Index (SMOGRA)</i>	<i>2.2 (m<sup>2</sup>/s<sup>2</sup> x 1000)</i>

Technical Director  
Xflam Pty Ltd

BRANZ Report FAR 2548 20 July 2005

### **PRODUCT**

### **SITUATION**

### **APPLICATION**

### **ISSUE**

### **BACKGROUND**

### **APPROVAL**

### **REFERENCES**